



中国国家强制性产品认证证书

证书编号: 2007010307221448

委托人名称、地址

LS产电

韩国京畿道安养市东安区LS-路127

生产者(制造商)名称、地址

LS产电

韩国京畿道安养市东安区LS-路127

生产企业名称、地址

LS产电株式会社清州1工厂

韩国忠清北道清州市兴德区白峰路95

产品名称和系列、规格、型号

塑料外壳式断路器

TS800E, TS800N, TS800S, TS800H, TS800P, TS800L ETS/ETM; 详见参数附件

产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2016年04月10日

有效期至: 2021年04月07日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2007年02月27日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1396240



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2007010307221448

NAME AND ADDRESS OF THE APPLICANT

LSIS Co.,Ltd.
127, LS-ro, DongAn-Gu, AnYang-Si, GyeongGi-Do, Korea

NAME AND ADDRESS OF THE MANUFACTURER

LSIS Co.,Ltd.
127, LS-ro, DongAn-Gu, AnYang-Si, GyeongGi-Do, Korea

NAME AND ADDRESS OF THE FACTORY

LSIS Co.,Ltd. Chengju 1 Plant
95, Baekbong-ro, HeungDeok-Gu, CheongJu-Si, ChungCheongBuk-Do, Korea

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-breaker

TS800E, TS800N, TS800S, TS800H, TS800P, TS800L ETS/ETM; See the Appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS
GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Apr.10,2016 Date of expiry: Apr.07,2021

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Feb.27,2007

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2007010307221448

纸号: 1396240

TS800E, TS800N, TS800S, TS800H, TS800P, TS800L ETS/ETM

Ui: 750V;

Ue: AC220V, 240V, 380V, 415V, 440V, 460V, 480V, 500V;

In: 630A, 800A;

过电流脱扣器类型: 电子式;

AC220/240V:E/N/S/H/P/L:Ics=Icu=85/100/120/120/150/200kA;

AC380/415V:E/N/S/H/P/L:Ics=Icu=50/65/85/100/130/150kA;

AC440/460V:E/N/S/H/P/L:Ics=Icu=50/65/85/100/120/130kA;

AC480/500V:E/N/S/H/P/L:Ics=Icu=42/42/65/85/85/100kA;

Icw= 10In/0.3s;

使用类别:A; 极数:3P,4P

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2007010307221448

纸号: 1396240

型号的解释:

TS 800 □ ETS

(TS800 → TS : Circuit Breaker Series Name, 800 : Ampere Frame)

电子式型	
ETS	标准型 : Overload Protection, Short-circuit Protection(short time, Instantaneous), Triping time delay
ET	复合型 : Overload Protection, Short-circuit Protection(short time, Instantaneous), Triping time delay, Earth fault protection, LED indication
M	

类型	
E	经济型
N	供应型
S	标准型
H	高断路型
P	限流型
L	超限流型

注: 此附录与证书同时使用时有效。



主 任 :

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

