



中国国家强制性产品认证证书

证书编号: 2014010307739928

委托人名称、地址

LS产电

韩国京畿道安养市东安区LS-路127

生产者(制造商)名称、地址

LS产电

韩国京畿道安养市东安区LS-路127

生产企业名称、地址

DAU INDUSTRY CO.LTD

468, Osangajwa-ro, Oksan-myeon, Cheong-won-gun, Chungcheongbuk-do, Korea

产品名称和系列、规格、型号

电动机保护用断路器

MMS-100H, MMS-100HI;详细参数请见附件

产品标准和技术要求

GB 14048.2-2008, GB 14048.4-2010

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求,特发此证。

发证日期: 2014年12月04日

有效期至: 2019年06月01日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1046732



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010307739928

NAME AND ADDRESS OF THE APPLICANT

LSIS Co., Ltd.
127, LS-ro, DongAn-Gu, AnYang-Si, GyeongGi-Do, Korea

NAME AND ADDRESS OF THE MANUFACTURER

LSIS Co., Ltd.
127, LS-ro, DongAn-Gu, AnYang-Si, GyeongGi-Do, Korea

NAME AND ADDRESS OF THE FACTORY

DAU INDUSTRY CO. LTD
468, Osangajwa-ro, Oksan-myeon, Cheong-won-gun, Chungcheongbuk-do, Korea

NAME, MODEL AND SPECIFICATION

Motor Protection Circuit-breaker

MMS-100H, MMS-100HI; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008 , GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-01C-011:2007).

Date of issue: Dec. 04, 2014 Date of expiry: Jun. 01, 2019

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:


Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 1046732



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2014010307739928

纸号: 1046732

MMS-100H, MMS-100HI; U_i : 1000V; U_e : AC230V/240V, 400V/415V, 440V/460V, 500V/525V, 600V/690V; I_n : 17A (I_R : 11A~17A), 22A (I_R : 14A~22A), 26A (I_R : 18A~26A), 32A (I_R : 22A~32A), 40A (I_R : 28A~40A), 50A (I_R : 34A~50A), 63A (I_R : 45A~63A), 75A (I_R : 55A~75A), 90A (I_R : 70A~90A), 100A (I_R : 80A~100A); 过电流脱扣器类型: 热磁式; I_{cs}/I_{cu} 详见下面附件; 脱扣级别: 10; 使用类别: A, AC-3; 3P

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2014010307739928

纸号: 1046732

附件:

额定电流 (A)	额定电压(V)									
	AC230V/240V		AC400V/415V		AC440V/460V		AC500V/525V		AC600V/690V	
	Icu(kA)	Ics(kA)	Icu(kA)	Ics(kA)	Icu(kA)	Ics(kA)	Icu(kA)	Ics(kA)	Icu(kA)	Ics(kA)
17	100	100	100	100	50	38	35	27	12	9
22	100	100	100	50	50	38	35	27	12	9
26	100	100	100	50	50	38	35	27	12	9
32	100	100	100	50	50	38	25	19	12	9
40	100	100	100	50	50	38	20	15	12	9
50	100	100	100	50	50	38	15	11	10	8
63	100	100	100	50	50	38	15	11	8	6
75	100	100	75	50	50	38	12	9	6	6
90	100	100	75	50	50	38	12	9	6	6
100	100	100	75	50	50	38	12	9	6	6

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

